

CHUGACH ELECTRIC ASSOCIATION, INC.  
Anchorage, Alaska

May 13, 2022

ADDENDUM #2

E1813857

C STREET: TUDOR & DIMOND INTERSECTION RELOCATION SOA

The following changes and additions have been made to the contract documents. Incorporate these changes and additions in your bid, sign the acknowledgement, and attach a signed copy of this addendum to your bid when submitted.

1. Questions & Answers for E1813857 C Street Tudor & Dimond Intersection Relocation SOA

Q1: Why is \*SUMH-810 listed twice on the assembly unit sheet?

A1: One is for removal the other is for abandonment, to be removed by DOT contractor. Both the SUMH-810 removal and abandonment are at the E. Dimond and C Street intersections. The vault to be removed is on the southwest corner of the intersection and the vault to be abandoned (which DOT is removing) is on the northeast corner of the intersection. Vault 4104 that is being abandoned has notes of such on the drawing and on the staking sheet page 4 of 5. Vault 3296 is slated to be removed and is also on the staking sheet page 4 of 5.

ACKNOWLEDGEMENT

The undersigned bidder hereby certifies that the revisions herein set forth have been incorporated in this bid and form a part of the contract documents.

\_\_\_\_\_  
Bidder

\_\_\_\_\_  
Address

\_\_\_\_\_  
Title

\_\_\_\_\_  
Date

APPROVED FOR DISTRIBUTION:

Victor R Willis 5-13-2022  
Victor Willis, Manager, Construction Engineering

May 13, 2022

E1813857