

CHUGACH ELECTRIC ASSOCIATION, INC.  
Anchorage, Alaska

May 8, 2025

ADDENDUM #2

E1713752  
Rosewood Park Estates CR

The following changes and additions have been made to the contract documents. Incorporate these changes and additions in your bid, sign the acknowledgement, and attach a signed copy of this addendum to your bid when submitted.

1. Q&A (attached).

ACKNOWLEDGEMENT

The undersigned bidder hereby certifies that the revisions herein set forth have been incorporated in this bid and form a part of the contract documents.

_____	_____
Bidder	Address
_____	_____
Title	Date

**APPROVED FOR DISTRIBUTION:** \_\_\_\_\_

  
Darvin Thornton, Manager, Distribution & Construction



**Chugach Electric Association, Inc  
E1713752 – Rosewood Park Estates CR  
Bid Questions and Responses and Exceptions**

- What DOT or MOA permits will be required for this project?
  - This project has no DOT involvement. The road crossings are all MOA.
- Are pedestals 2929, 3529, 2905 and 3505 being replaced or just new feeds?
  - The intention is to just replace the secondary on PED 2929, 3529, 2905, and 3505 and re-use the existing PEDs.
- Is it CEA's intent to have the Contractor perform the switching for this project?
  - CEA's intent is for Contractor to do switching in accordance with current OELCC and signed OELCC Amendment.
- Are all of the primary cable runs being replaced currently energized?
  - As of 5/8/2025 there is only one Utility Hold (19-00013-UH) on this project and that is for the section of conductor between PM 1806 and PM 3405.
- Will CEA secure access to the easement with the property owners?
  - The CEA Contractor will be responsible for securing access to the easement with the property owners. Chugach inspectors will be available to assist if Contractor is unable to secure access to the easement.
- The bore unit cost is based on the provided information on the drawings and staking sheets. Any changes to the quantities, distances, or any other differences will result in a different unit cost.
  - Any change in bore quantities or distances will be handled using the ICOR process outlined in the OELCC and signed OELCC Amendment.

**There were no acceptable exceptions provided during the question period of this bid.**