

CHUGACH ELECTRIC ASSOCIATION, INC.  
Anchorage, Alaska

June 19, 2023

ADDENDUM #2

**E2114054**  
**COMMUNICATIONS TRACT 1 RELOCATION**


The following changes and additions have been made to the contract documents. Incorporate these changes and additions in your bid, sign the acknowledgement, and attach a signed copy of this addendum to your bid when submitted.

1. Q & A (attached).

ACKNOWLEDGEMENT

The undersigned bidder hereby certifies that the revisions herein set forth have been incorporated in this bid and form a part of the contract documents.

_____	_____
Bidder	Address
_____	_____
Title	Date

**APPROVED FOR DISTRIBUTION:**   
Mike Miller (Jun 19, 2023 13:13 AKDT)  
Darvin Thornton, Manager, Construction Engineering



Chugach Electric Association  
E2114054 – Communications Tract 1 RELO  
Bid Questions and Responses

- 1. Will all circuits in the new vault and existing vaults need to be fire taped?
  - All new circuits in vaults must be fire taped.
- 2. Will all circuits in the Pull Box need to be fire taped?
  - All new circuits installed in a pull box with multiple circuits (existing or new) must be fire taped.
- 3. Is fire tape contractor supplied?
  - Yes.
- 4. Can substantial completion and final completion dates be extended?
  - Chugach does not anticipate a need to extend completion dates. A contractor who is awarded the contract can submit a request for extension should changes in project scope or other unanticipated conditions exist in the field.

Chugach Electric Association, Inc.

5601 Electron Drive, P.O. Box 196300, Anchorage, Alaska 99519-6300 • (907) 563-7494 Fax (907) 562-0027 • (800) 478-7494  
[www.chugachelectric.com](http://www.chugachelectric.com) • [info@chugachelectric.com](mailto:info@chugachelectric.com)