

CHUGACH ELECTRIC ASSOCIATION, INC.  
Anchorage, Alaska

June 29, 2026

ADDENDUM #2

E2214138 – West Perimeter Airport Road System Improvement

The following changes and additions have been made to the contract documents. Incorporate these changes and additions in your bid, sign the acknowledgement, and attach a signed copy of this addendum to your bid when submitted.

1. Q&A (attached).

ACKNOWLEDGEMENT

The undersigned bidder hereby certifies that the revisions herein set forth have been incorporated in this bid and form a part of the contract documents.

\_\_\_\_\_  
Bidder

\_\_\_\_\_  
Address

\_\_\_\_\_  
Title

\_\_\_\_\_  
Date

**APPROVED FOR DISTRIBUTION:** *Darvin Thornton*  
Darvin Thornton  
Senior Manager, Distribution Design and Construction



**Chugach Electric Association, Inc  
West Perimeter Airport Road – E2214138  
Bid Questions and Responses and Exceptions**

- What is required to get access inside the runway fence area?
  - Access to the runway area requires a TSAIA SIDA badge or an escort by someone who carries that card.
- Can CEA provide a sheet with the generator size, voltage, and customer contact per transformer?
  - Yes. See sheets attached.

**There were no acceptable exceptions provided during the question period of this bid.**

Chugach Electric Association, Inc.

5601 Electron Drive, P.O. Box 196300, Anchorage, Alaska 99519-6300 • (907) 563-7494 Fax (907) 562-0027 • (800) 478-7494  
www.chugachelectric.com • info@chugachelectric.com

Transformers demand that may be affect from E2214138 work

GRID: 1722

- PM 4127, 25 KVA, 120/240V
  - 1 KW

GRID: 1822

- PM 1065, 150 KVA, 120/208V
  - 40.8 KW

GRID: 1820

- PM 9308, 150 KVA, 277/480V
  - 0.05 KW
- PM 9408, 300 KVA, 120/208V
  - 82.75 KW
- PM 9720, 75 KVA, 277/480V
  - 3.53 KW

Grid: 1920

- PM 3358A, 25 KVA, 120/240V
  - 3.69 KW
- PM 3458, 150 KVA, 277/480V
  - 144 KW
- PM 7146, 25 KVA, 120/240V
  - 5.03 KW
- PM 0326, 25 KVA, 120/240V
  - 0.01 KW
  - 2.26 KW

GRID: 2019

- PM 8587, 25 KVA, 120/240V
  - 0.59 KW

GRID: 2024

- PM 3816, 25 KVA, 120/240V
  - 0.49 KW

Transformers demand that may be affect from E2214138 work

GRID: 1722

- PM 4127, 25 KVA, 120/240V
  - 1 KW
    - TESORO AK PET CORP - (907)561-5521
    - TSAIA FACILITIES MAINTENANCE – (907)266-2432

GRID: 1822

- PM 1065, 150 KVA, 120/208V
  - 40.8 KW
    - TSAIA FACILITIES MAINTENANCE – (907)266-2432

GRID: 1820

- PM 9308, 150 KVA, 277/480V
  - 0.05 KW
    - MOA – (907)343-6576
- PM 9408, 300 KVA, 120/208V
  - 82.75 KW
    - MOA – (907)343-6576
- PM 9720, 75 KVA, 277/480V
  - 3.53 KW
    - MOA – (907)343-6576

Grid: 1920

- PM 3358A, 25 KVA, 120/240V
  - 3.69 KW
    - TSAIA FACILITIES MAINTENANCE – (907)266-2432
- PM 3458, 150 KVA, 277/480V
  - 144 KW
    - TSAIA FACILITIES MAINTENANCE – (907)266-2432
- PM 7146, 25 KVA, 120/240V
  - 5.03 KW
    - TSAIA FACILITIES MAINTENANCE – (907)266-2432
- PM 0326, 25 KVA, 120/240V
  - 0.01 KW
    - TSAIA FACILITIES MAINTENANCE – (907)266-2432
  - 2.26 KW

- TSAIA FACILITIES MAINTENANCE – (907)266-2432

GRID: 2019

- PM 8587, 25 KVA, 120/240V
  - 0.59 KW
    - TSAIA FACILITIES MAINTENANCE – (907)266-2432

GRID: 2024

- PM 3816, 25 KVA, 120/240V
  - 0.49 KW
    - TSAIA FACILITIES MAINTENANCE – (907)266-2432